




**EU Declaration of Conformity**

The Manufacturer:

**BARTEC VARNOST d.o.o.**  
**Cesta 9. Avgusta 59**  
**1410 Zagorje ob Savi**  
**Slovenia**

declares under the sole responsibility that the products: 3-phase induction motors

Marking	Motor type	EU-Type Examination Certificate
II 2 G Ex db IIC T* Gb or  II 2 G Ex db eb IIC T* Gb	4KTC 71 - 225	BVS 13 ATEX E 125 X Supplement 2
 II 2 D Ex tb IIIC T*°C Db	4KTCD 71-225	
II 2 G Ex db IIB T* Gb or	4KTB 71 - 225	
 II 2 G Ex db eb IIB T* Gb		

**Notified Bodie (ExNB):** 0158, DEKRA Testing and Certification GmbH, Dinnendahlstrasse 9, 44809 Bochum, Germany

are in conformity with provisions of the following Union harmonization legislation:

**Directive 2014/34/EU**

and with the following standards:

EN 60079-0:2018, EN 60079-1:2014, EN 60079-7:2015 + A1:2018, EN 60079-31:2014 and relevant parts of the EN 60034-series of standards.

**Directive 2009/125/EC**

The motors are in conformity with the requirements set in the Commission Regulation EU 2019/1781 of 25 October 2019 and amendment EU 2021/341 of 26 February 2021 from 1st of July and onwards.

Standards which are applied are EN 60034-2-1:2014 and EN 60034-30-1.

According to the Regulation (EU) 2019/1781 (Article 2, 2m), motors placed on the market before 1 July 2029 as substitutes for identical motors integrated in products placed on the market before 1 July 2021, and specifically marketed as such, are exempt from the efficiency requirements.

**Directive 2011/65/EU** and with the amending Annex II to this Directive of the Delegated Directive (EU) 2015/863 on the restriction of the use of certain hazardous substances in electrical and electronic equipment. Technical documentation based on EN IEC 63000:2018

The indicated product is intended for fitting into a machine. The conformity of the end product according to the Directive 2006/42/EC has to be established by the commissioning party when the motor is fitted to the machinery.

**Note:** When installing motors for converter supply applications additional requirements must be respected regarding the motor as well as the installation.

The sign »X« placed after the certificate number indicates that the repair of the flameproof joints with the values in table 3 of EN 60079-1:2014 is not accepted and that the equipment is subject to special conditions for safe use which are prescribed in the manual.


Motors which have to be equipped with a direct temperature control must be monitored by a separately certified trigger unit.

If the electrical machine will be cooled by forced ventilation, it has to be assured that the electrical machine can only run if the ventilation is running.

The Quality Assurance system certified by Notified Bodies (Ex NB):  
 1304, SIQ Ljubljana, Mašera Spasičeva ulica 10, SI-1000 Ljubljana, Slovenia

Date: 28.05.2021

Signed by

  
 Janez Gajski

Title

QM / ATEX Representative